

## **Fire Safety Nominated Supervisor**

NQS Element 2.2.2 Incident and emergency management

Name of the person conducting the checklist:	Date:		
Testing  Smale detectors are tested every month by pressing test button	OYes	ONo	ONA
Smoke detectors are tested every month by pressing test button	O Yes	ONo	ONA
Batteries in smoke detectors are replaced annually All fire extinguishers are tested every 6 months	O Yes	ONo	ONA
All fire blankets are tested every 6 months	O Yes	ONo	ONA
Fire equipment is within expiry period ie current	O Yes	ONo	ONA
Display	<u> </u>	0110	ONA
Emergency plans is displayed in all rooms near exits	O Yes	ONo	ONA
	O Yes	ONo	ONA
Evacuation procedures are displayed in all rooms near exits	O Yes	ONo	ONA
Exit signs are displayed to identify exits	O Yes	ONo	ONA
Emergency telephone numbers are displayed  Facilities	<u> </u>	ONO	ONA
	OYes	ONo	ONA
Heating cooling units are inaccessible to children	Oyes	ONo	ONA
Exit doors are always clear of obstructions/objects	Oyes	ONo	ONA
Exit doors are unlocked when service is open			ONA
There are no leaves or litter in the environment	O Yes	O No O No	ONA
Gutters are cleaned regularly		ONo	ONA
Lint is cleaned from the clothes dryer filter after every use	O Yes	ONo	ONA
Insurance policies are up to date and cover relevant emergencies like fire	O Yes	ONO	ONA
Consultation		ONo	ONA
Relevant authorities are consulted where necessary eg for advice about location of	O Yes	ONO	ONA
assembly point, development of emergency procedures  Rehearsals			
Evacuation procedures are rehearsed at least once every three months on different days	OYes	O No	ONA
and at different times	, O 163	ONO	ONA
Everyone at the service participates in the rehearsal, including owners and managers	O Yes	O No	ONA
The emergency kit is fully stocked	O Yes	O No	ONA
Daily Practices			
Children's art work/displays are kept away from heating/cooling units	O Yes	ONo	ONA
Curtains and tablecloths etc are kept away from heaters	O Yes	O No	ONA
Power points are not overloaded	O Yes	O No	ONA
Appliances are switched off when not in use	O Yes	O No	ONA
Flammable chemicals are stored safely eg not near materials like art paper	O Yes	ONo	ONA
Cooking is never left unattended	O Yes	O No	ONA
Practices in Emergency			
Attendance records (children and staff) are collected and checked to ensure everyone is	O Yes	O No	ONA
accounted for			
Specific person collects emergency kit	O Yes	O No	ONA
Specific person takes charged mobile phone with credit	O yes	ONo	ONA
Diary Notes			
There is a diary note to test smoke detector monthly	O yes	ONo	ONA

Copyright Centre Support Pty Ltd 2021 The service who has purchased this Toolkit resource is the only service that can use this document. No part of this document can be copied, distributed, passed on or given to a friend outside the service who has not purchased the Centre Support Product. If this occurs Centre Support will take legal action against you personally and the person who has received it. . P a g e | 1



There is a diary note to change batteries in smoke detector annually	O Yes	ONo	ONA
Actions required			